City of Carmel Utilities

3450 W. 131st. Street
Carmel, In. 46074

317-733-2855
Fax: 317-733-2053

INSIDE METER SPECS 5/8 x 3/4" – 1"

ITEM #	DESCRIPTION	5/8" X 3/4" METERS	1" METERS
1.	**SERVICE LINE**	3/4" K COPPER	1" K COPPER
2.	**YOKE**	FORD Y502 MUELLER H5020-203 AY MCDONALD 14-2	FORD Y504 MUELLER H5040-330 AY MCDONALD 14-4
3.	**STREET SIDE ANGLE VALVE**	FORD AV94-323W AY MCDONALD 4602Y-223/AX02 MUELLER 12463	FORD AV94-444W AY MCDONALD 45602Y-22 1X04 MUELLER
4.	**HOUSE SIDE ANGLE VALVE**	FORD AV94-323W AY MCDONALD 4602Y-223/AX02 MUELLER 12463	FORD AV94-444W AY MCDONALD 45602Y-22 1X04 MUELLER
5.	**APPROVED BACKFLOW**	DIRECTLY BEHIND METER. RP. DOUBLE CHECK	

NOTE:

THEIR WILL BE A $56.00 RE-INSPECT FEE FOR EACH ADDITIONAL INSPECTION.

IF THE INSIDE SET IS BELOW GROUND LEVEL. YOU ARE REQUIRED TO RUN A CONDUIT WITH WIRE TO LOCATE OUR RADIO TRANSMITTER AT GROUND LEVEL OR ON AN OUTSIDE WALL.