



City of Carmel
Building & Code Services
1 Civic Square, Carmel, IN 46032
(317) 571-2444

Solar Inspection Pre-check List for City of Carmel Inspection

1. All work to be done in a neat and workmanlike manor to ensure livable and Safe Housing.
2. System installed as designed, permitted and to code.
3. All labels installed on all devices and conduit.
4. System turned off for inspection.
5. Meter is to be removed if any electrical panel has been replaced and covers of electrical panels removed for inspection of wiring and components.
6. All bonding and grounding of devices, arrays and racks is to code and/or manufactures specifications.
7. All devices and arrays securely fastened with required spacing for arrays as well as clear workspaces for all devices.
8. All penetrations flashed and sealed.
9. All cables are properly secured, sized, rated and routed for applications.
10. Rapid shut down installed and operational.
11. Fire access according to design and code.

**** All interconnected electric power production sources other than the utility must be identified in a permanently mounted sign/label at the service entrance. The locations of disconnects for any power production sources must be on that permanently mounted sign/label if those disconnects are not located at the service disconnecting means. ****

For any questions related to the inspection, please call 317-571-2481.